

12LCP-9

12 V 9 Ah



Q-Batteries Akku 12LCP-9 battery is a special deep cycle battery which is designed for intensive cyclic discharge usage. Because of the very thick lead plates it's possible to achieve more cycles and longer lifetime.

Application:

Electric wheelchair, caravan/marine, cleaning machines, golf cart, vehicle lifts, solar energy system, u.v.m.











Specification:

Voltage Per Unit 12 V

Capacity 9 Ah @20hr-rate to 1.8V per cell @25°C

Cells Per Unit 6

Weight ca. 2.55 kg +/- 3%

Max. Discharge Current 80 A (5 sec.) Internal Resistance ca. 18 m Ω

Operating Temperature Range Discharge: Charge: Storage:

Normal $-15^{\circ}\text{C} - 50^{\circ}\text{C} - 10^{\circ}\text{C} - 50^{\circ}\text{C} - 20^{\circ}\text{C} - 50^{\circ}\text{C}$

Operating Temperature Range 25°C ± 5°C

Self Discharge Valve Regulated Lead Acid (VRLA) batteries can be stored for


more than 6 months at 25°C. Self-discharge ratio less than 3% per month at 25°C. Please charge batteries before using.


Terminal F1/F2 (Faston 4,75mm/6,35mm)


Container Material A.B.S. (UL94-HB)

Dimensions:

151 Length x 65 Width x 94 mm Height











Constant current discharge characteristics: A (25°C)

F.V/Time	5 Min.	10 Min.	15 Min.	30 Min.	1 HR	2 HR	3 HR	4 HR	5 HR	8 HR	10 HR	20 HR
9.60 V	36.05	23.63	18.53	10.40	6.179	3.559	2.418	1.935	1.607	1.024	0.886	0.486
10.0 V	34.74	23.04	17.93	10.27	6.010	3.487	2.374	1.908	1.580	1.019	0.877	0.479
10.2 V	32.70	21.90	17.43	10.11	5.954	3.450	2.353	1.890	1.563	1.010	0.864	0.471
10.5 V	29.40	20.48	16.44	9.830	5.837	3.405	2.332	1.871	1.544	1.001	0.859	0.450
10.8 V	26.34	19:10	15.51	9.506	5.731	3.377	2.304	1.862	1.528	0.997	0.845	0.430
11.1 V	23.04	17.51	14.31	9.144	5.577	3.241	2.259	1.846	1.512	0.989	0.832	0.423
	•	•				•						

Life characteristics of cyclic use



Storage characteristic



Supplementary charge required (Carry out suppleentary charge before use if

Supplementary charge required before use. This supplementary charge will help to recover the capacity and should be made

Supplementary charge may capacity. The battery should never be left standing till this

Supplementary charge and

Capacity Factors with different Temperature

Battery Type		-20°C	-10°C	0°C	5°C	10°C	20°C	25°C	30°C	40°C	45°C
GEL	6V & 12V	50%	70%	83%	85%	90%	98%	100%	102%	104%	105%
Battery	2V	60%	75%	85%	88%	92%	99%	100%	103%	105%	106%
AGM	6V & 12V	46%	66%	76%	83%	90%	98%	100%	103%	107%	109%
Battery	2V	55%	70%	80%	85%	92%	99%	100%	104%	108%	110%

Charging Method

Charge the batteries at least once every six months, if they are stored at 25°C

Constant Voltage (V)	-0.2C x 2h + 2.4–2.45V/Cell x 24h, max. Current 0.3CA
Constant Current (A)	-0.2C x 2h + 0.1CA x 12h
Fast	-0.2C x 2h + 0.3CA x 4.0h